

Customer No.: **AJM** Inspect. rec. No.: **2021** Order No.: **2021**



ELECTRICAL EQUIPMENT TEST REPORT - TEST RESULTS

PAT PRO

Appliance Description	ID	P/F	Retest date	Visual Test	Earth Bond	Insulation	Isolation Probe	Subleak	Subleak Probe	Leakage	Touch Leakage	Clamp	Functional Test	PRCD ²	POL ³
				(all)	(Ω)	(MΩ)	(MΩ)	(mA)	(mA)	(mA)	(mA)	(A)	(kVA)	(ms)	

Andrew James Music

Portable

IEC lead															
User :															
Serial : 12011575															
001	P			P	0.19 P	>200 P									P
Keyboard															
User :															
Serial : 12011575															
002	P			P		>200 P		0.02 P							
IEC lead															
User :															
Serial : 12011575															
003	P			P	0.06 P	>200 P									P
Extension lead															
User :															
Serial : 12011575															
004	P			P	0.16 P	>200 P									P
Apple charger															
User :															
Serial : 12011575															
005	P			P		>200 P		0.00 P							
IEC lead															
User :															
Serial : 12011575															
006	P			P	0.08 P	>200 P									P
IEC lead															
User :															
Serial : 12011575															
007	P			P	0.13 P	>200 P									P

1) Worst result is reported

2) Result of 1xIΔN, 0° is reported. If any RCD result failed, a fail (F) is reported

3) Polarity

4) P* appears if autotest is not completely finished

Signature: _____ Customer: _____ Operator: _____

Customer No.: **AJM** Inspect. rec. No.: **2021** Order No.: **2021**



ELECTRICAL EQUIPMENT TEST REPORT - TEST RESULTS

PAT PRO

Appliance Description	ID	P/F	Retest date	Visual Test	Earth Bond	Insulation	Isolation Probe	Subleak	Subleak Probe	Leakage	Touch Leakage	Clamp	Functional Test	PRCD ²	POL ³
				(all)	(Ω)	(MΩ)	(MΩ)	(mA)	(mA)	(mA)	(mA)	(A)	(kVA)	(ms)	

Andrew James Music

Portable

Speaker															
User :															
Serial : 12011575															
015		P		P		>200 P		0.03 P							
Nord drum adaptor															
User :															
Serial : 12011575															
016		P		P		>200 P		0.00 P							
Nord drum															
User :															
Serial : 12011575															
017		P		P		>200 P		0.00 P							

1) Worst result is reported
 2) Result of 1xΔN, 0° is reported. If any RCD result failed, a fail (F) is reported
 3) Polarity
 4) P* appears if autotest is not completely finished

Signature: _____ Customer: _____ Operator: _____